

RESIDENTIAL AND COMMERCIAL CONSTRUCTION HANDBOOK FOR NEW SERVICES



Touchstone Energy[®]
Cooperatives

The power of human connections[®]



**West River Electric
Association, Inc.**

"Powering You For A Brighter Future"



TABLE OF CONTENTS

Introduction	01
MEMBER/CONTRACTOR NEW SERVICE CHECKLIST	CHECK-1
OVERHEAD CONDUCTOR CLEARANCE REQUIREMENTS	CLEARANCES-1
OVERHEAD CONDUCTOR CLEARANCE REQUIREMENTS	CLEARANCES-2
METER CLEARANCE REQUIREMENTS	CLEARANCES-3
TRANSFORMER CLEARANCES REQUIREMENTS	CLEARANCES-4
BOLLARD CONSTRUCTION GUARDING REQUIREMENTS	GUARD-1
BOLLARD PLACEMENT GUARDING REQUIREMENTS	GUARD-2
METER CAN METER REQUIREMENTS	METER-1
METER CAN INSTALLATION METER REQUIREMENTS	METER-2
WREA PPROVED CT CABINET METER REQUIREMENTS	METER-3
WREA APPROVED METER CAN METER REQUIREMENTS	METER-4
CT METER CAN WITH TEST SWITCHES METER REQUIREMENTS	METER-5
TYPICAL BASEMENT INSTALLATION PAD REQUIREMENTS	PAD-1
REQUIREMENTS PERMANENT SERVICE REQUIREMENTS	PERM-1
320 AMP UNDERGROUND PERMANENT SERVICE	PERM-2
320 AMP OVERHEAD PERMANENT SERVICE	PERM-3
320 AMP OVERHEAD TO STRUCTURE PERMANENT SERVICE	PERM-4
3Ø TRANSFORMER PAD PERMANENT SERVICE	PERM-5
3Ø TRANSFORMER WITH SECONDARY PAD PERMANENT SERVICE	PERM-6
STEEL POST PERMANENT SERVICE	PERM-7
CT CABINET METERING PERMANENT SERVICE	PERM-8
CT'S IN TRANSFORMER METERING PERMANENT SERVICE	PERM-9
GANG METER MODULES PERMANENT SERVICE	PERM-10
MOBILE HOME PERMANENT SERVICE	PERM-11
REQUIREMENTS TEMPORARY SERVICE	TEMP-1
UNDERGROUND METER MOUNTING TEMPORARY SERVICE	TEMP-2
OVERHEAD METER MOUNTING TEMPORARY SERVICE	TEMP-3
URD CABLE AND TRENCHING TRENCH REQUIREMENTS	TRENCH-1
TYPICAL TRENCH PROFILE TRENCH REQUIREMENTS	TRENCH-2

INTRODUCTION

West River Electric Association (WREA) is providing this handbook of service specifications and drawings. This handbook is intended to be used when bidding, installing, or upgrading service entrances in WREA service territory. If specifications cannot be followed, then prior approval shall be obtained from WREA before proceeding.

This handbook is based on the current versions of the NEC & NESC. This handbook does not take precedence or redefine requirements in any Codes. Please consult with authority having jurisdiction in project area for compliance requirements.

WREA may update this booklet as deemed necessary at any time. For questions, please contact the staking personnel in the Rapid City office.

Last updated 03/23/2020

Contact Information:

West River Electric Association, Inc.

1200 West Fourth Ave. - P.O. Box 412

Wall, SD 57790

(605) 279-2135

(888) 279-2135

Fax # (605) 342-9587

<http://westriver.coop>

West River Electric Association, Inc.

3250 East Hwy 44

Rapid City, SD 57703

(605) 393-1500

(888) 393-1500

Fax # (605) 393-0275

<http://westriver.coop>

West River Electric Association

Service can be started after these items are completed by Member/Contractor

- ☐ Provide service description and information (i.e. pump, irrigation, seasonal, residential, commercial, type of heat, demand controller, etc.)
- ☐ Provide service requirements including voltage, amperage and number of phases
- ☐ Provide 911 address of new service
- ☐ Provide courthouse copy of plat and deed for service location
- ☐ If crossing neighbor's property, provide courthouse copy of neighbor's plat and deed
- ☐ Complete WREA new service application and new membership form
- ☐ Provide a photo ID
- ☐ Complete signatures on all required easements
- ☐ Complete and sign "Line Extension Agreement"
- ☐ Make applicable payments such as service charge, line extension costs, or aid of construction
- ☐ Pay either a deposit or have good credit reference with another utility or acceptable credit per a credit bureau check
- ☐ Remove trees or vegetation required by WREA
- ☐ Contact other utilities and coordinate installation of other utilities with WREA
- ☐ Contact SD One Call, 811 or 1-800-781-7474
- ☐ Supply approved trench, bedding, and backfill at appropriate times
- ☐ City or state inspection of service completed
- ☐ Wiring certificate and permit for temporary service at WREA office
- ☐ Inspection blue sticker attached to the meter socket

DESIGN: SRB

DRAWING:SRB


APPROVED BY DATE
SRB 02-20

MEMBER/CONTRACTOR NEW SERVICE CHECKLIST



REV. DATE REV. NO.
02-20 1

DRAWING NUMBER
CHECK-1



(NOT TO SCALE)

Overhead conductor clearances are listed below from the NEC and NESC. The overhead line shall never be lower than the values listed. Local requirements may vary, Member/Contractor shall consult with the authority having jurisdiction to ensure regulatory compliance.


1. 10'-6" – Above sidewalks or from platforms or projections from which reached or accessible to only pedestrians (0-300V)
2. 12'-6" – Over residential property and driveways & those commercial areas such as parking lots and drive-in establishments not subject to truck (0-388V)
3. 16'-0" – Over commercial areas, parking lots, agricultural or other areas subject to truck traffic
4. 18'-0" – Over public streets, alleys, roads and driveways on other than residential property subject to truck
5. 3'-0" – Horizontal clearance in all directions from the edge of the roof

DESIGN: M.S.
DRAWING: A.K.
APPROVED BY: M.S.
DATE: 1/2007

OVERHEAD CONDUCTOR CLEARANCE REQUIREMENTS



REV. DATE 02-20	REV. NO. 4
DRAWING NUMBER CLEARANCES-1	



(NOT TO SCALE)

Overhead conductor clearances are listed below. These are directly from the latest NEC and NESC. Overhead lines shall never be lower than the values listed. Keep in mind lines will be lower during hot weather, ice loading, or other abnormal conditions. Local regulations may vary, Member/Contractor shall consult with the authority having jurisdiction to ensure regulatory compliance.

1. 12' – Above balcony, fire escapes, or any area subject to pedestrian occupation
2. 5' from any window
3. 3'–6" clearance over any roof with a slope greater than 4/12. Building is not being serviced by the line. WREA prohibits line to pass over roof of same structure being served by overhead electric lines.

DESIGN: M.S.	
DRAWING: A.K.	
APPROVED BY M.S.	DATE 1/2007


OVERHEAD CONDUCTOR CLEARANCE REQUIREMENTS



**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE 02-20	REV. NO. 4
DRAWING NUMBER CLEARANCES-2	

GAS EQUIPMENT



(NOT TO SCALE)

Local requirements may vary, Member/Contractor shall consult with the authority having jurisdiction to ensure regulatory compliance.


1. 3' – Measured horizontally from any gas equipment
2. 3' – Measured horizontally from any air vents, downspouts, or anything that may drip water/moisture from above
3. 3' – From any structure opening (e.g. window, door, air intake, etc..)
4. 3' – All directions from any obstruction (e.g. shrubs, A/C equipment, etc.)
5. Meter shall not be enclosed inside buildings, porches, or anywhere which inhibits access to WREA personnel
6. Meter shall not be located under or over decks

DESIGN: M.S.
DRAWING: A.K.
APPROVED BY: M.S.
DATE: 10/2019

METER CLEARANCE REQUIREMENTS



REV. DATE: 02-20
REV. NO.: 2
DRAWING NUMBER: CLEARANCES-3



Notes:


1. The sections listed below are found in this booklet and apply to this drawing.
 - a. GUARDING REQUIREMENTS
 - b. CLEARANCE REQUIREMENTS
10. Transformers shall be located in areas:
 - a. Easily accessible to WREA personnel and equipment
 - b. Protected from landslides, flooding, land movement, etc...
11. Member/Contractor shall not install any fencing, enclosures, retaining walls, etc. around transformer without contacting WREA for approval.
12. Member/Contractor shall install and maintaining safeguards for transformer (e.g. retaining walls, bollards, etc...)
13. Transformer shall have 10' of working space directly in front of the doors free and clear of items at all times.
14. Transformer shall have greater than the minimum clearances shown in figures 1 and 2.
15. Transformer shall not be located within 5' of fire or water hydrants

DESIGN: M.S.
DRAWING: A.K.
APPROVED BY: M.S. DATE: 10/2019

**TRANSFORMER
CLEARANCE REQUIREMENTS**



REV. DATE: 02-20 REV. NO.: 2
DRAWING NUMBER: CLEARANCES-4



(NOT TO SCALE)

Notes:

1. The sections below are found in this booklet and apply to this drawing.
 - a. GUARDING REQUIREMENTS
10. 4" standard galvanized pipe
11. 5" standard galvanized pipe for removable bollard to set into
12. End cap
13. Concrete dome top, pipe shall be free of sharp edges
14. Removable bollard filled with cured concrete before installation, approximate weight 150 lbs
15. 3/4" galvanized bolt to set removable bollard height
16. Drill weep holes as needed to avoid pipe burst from water freezing
17. Bollards shall be painted yellow

DESIGN: SRB

DRAWING: SRB

APPROVED BY: SRB
DATE: 02-20

BOLLARD CONSTRUCTION
GUARDING REQUIREMENTS



**West River Electric
Association, Inc.**


Your Touchstone Energy® Cooperative

REV. DATE
02-20

REV. NO.
1

DRAWING NUMBER

GUARD-1



(NOT TO SCALE)

Notes:

1. The sections below are found in this booklet and apply to this drawing.
 - a. GUARDING REQUIREMENTS
 - b. CLEARANCE REQUIREMENTS
10. Any equipment located in areas close to or adjacent to vehicle traffic shall be protected per the NEC.
11. Member/Contractor shall provide protection at the request of and which is acceptable to WREA.
12. Bollards shall be removable if they prevent WREA from accessing equipment, interfere with operation of equipment doors, or at the request of WREA.
13. Bollards shall be installed 2' from the equipment
14. Bollards shall not exceed 5' spacing
15. Building walls will provide acceptable guarding if located consistent with bollard requirements above
16. Square faced street curb parallel to normal traffic flow will provide acceptable guarding if equipment is located 6' or more behind the curb.
17. Bollards shall be 4' or greater from any fire hydrant

DESIGN: SRB	
DRAWING: SRB	
APPROVED BY SRB	DATE 02-20

BOLLARD PLACEMENT GUARDING REQUIREMENTS



REV. DATE 02-20	REV. NO. 1
DRAWING NUMBER GUARD-2	

METER REQUIREMENTS

1. Checklist in this booklet completed
2. Meter can must be ringless type, WREA approved, and installed level in all directions
3. All meter sockets shall be rated 200 amp unless WREA approves otherwise
4. Member/Contractor disconnect equipment must be weatherproof, covered when inspected, and installed per NEC
5. All meters shall be outside of buildings and accessible to WREA employees.
6. Meter base and conduit must be securely attached to temporary or permanent structures.
7. Commercial or 320 amps meter service shall have a lever bypass socket.
8. Member/Contractor shall provide and install a WREA approved CT cabinet and 13 terminal meter socket when required. All current metering will be done at 120 volts. See CT cabinet drawings in this booklet.
9. All elbows shall be of the long sweep type when conduit is used on the line side of meter
10. Service disconnect shall be installed on the load side or adjacent to the meter housing if a self contained meter housing is not attached to a building. Both the disconnect and conductor on the load side shall be Member/Contractor furnished and maintained.
11. All conduits shall be schedule 80 above grade per the NEC
12. When using a multiple meter housing, the service shall be clearly marked and securely attached to the meter socket.
13. For the following drawings, a number in a bubble "##" references to the note at the bottom of the page.

DESIGN: M.S.

DRAWING: A.K.

APPROVED BY: M.S. DATE: 05/19


METER CAN METER REQUIREMENTS



**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE: 02-20 REV. NO.: 2

DRAWING NUMBER
METER-1



NOTES:

(NOT TO SCALE)

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
10. Ground wire shall be #6 minimum installed in separate conduit per NEC
11. 8' long 5/8" diameter ground rod shall be driven not laid in the ditch per the NEC
12. Conduit shall come into the bottom of meter can on right or left side not in the center.
13. Protective bushing required on all conduit ends above or below grade
14. Meter height shall be as shown
15. Disconnect per the NEC

DESIGN: SRB

DRAWING: SRB

APPROVED BY: SRB
DATE: 02-20

METER CAN INSTALLATION
METER REQUIREMENTS



**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative




REV. DATE: 02-20
REV. NO.: 1

DRAWING NUMBER
METER-2

- 1- INTERNAL TRANSFORMER CABINET COMPLETES WITH A "NATIONAL ELECTRICAL CODE" DOOR AND (3) HINGES WITH 3 POINT DOOR LATCH AND PALCOBACKABLE HANDLE
- 2- 14 GA. GALV. STEEL MOUNTING PAN WITH 1 3/8" INSULATING SUPPORTS FOR BUS WORK.
- 3- TWO 1/2" TRANSFORMER MOUNTING BOLTS, 1 3/4" LONG
- 4- 3/8" LUG MOUNTING POWER COIL G.T.S.
- 5- COPPER-ALUMINUM (1) 750CMH-46 OR (2) 300CMH-46
- 6- NEUTRAL OR GROUNDING CONDUCTOR PROVIDED WITH 1/2" COPPER-ALUMINUM (1) 750CMH-46
- 7- CENTER POSITION - IS NOT REQUIRED IF SERVICE IS 14,300 V.
- 8- SHIELDING LUG / TEMPORARY SUPPORT INSTALLED ON EACH PHASE

* PULV CURRENT RATINGS FOR ALL APPENDAGES 85,000 AMPS AT 6000V WITH NO CABLE BRACING REQUIRED.

- WIND CATCH ON EXTERIOR DOOR
- MOUNTING HARDWARE FOR UTILITY
- NEUTRAL PROVIDED WITH (1) #10-24NC BOLT
- LUGS PROVIDED ON TOP PADS ONLY (LOAD SIDE)
- UTILITY SUPPLIES THE LUGS FOR BOTTOM PADS (LINE SIDE)



PHASE BUS PAD DETAILS

***APPROVED FOR LINE & LOAD CONDUCTORS
TO ENTER AND EXIT SAME END OF ENCLOSURE***

AMPACITY	LUGS	MINIMUM DIMENSION											CATALOG NUMBER			
		A	B	C1	C2	D	E	F	G	H	CABINET	3 rd CABINET	1 st CABINET			
400	1	48"	36"	11.00"	21.00"	4.125"	10.50"	7"	15"	4.5"	CR48SL	BHCT48-4TM	BHCT48-3TM			
600/800	2/3	48"	36"	11.00"	21.00"	4.125"	10.50"	7"	15"	4.5"	CR48SL	BHCT68-4TM	BHCT68-3TM			


NOTE: FOR SINGLE PHASE UNITS, OMIT Ø BUS ASSEMBLY

DATE OF BIRTH	WEST RIVER ELECTRIC METTERING TRANSFORMER CABINET APPROVAL DRAWINGS	TYPE	400-500 AMP 480 VOLT OR LESS CURRENT TRANSFORMER CABINET
NAME	JK	DATE	03/24/20
ADDRESS	03/24/20	DATE	03/24/20
PHONE	NTS	DATE	03/24/20
EMAIL	NTS	DATE	03/24/20
CONTROL NUMBER	AMERICAN MIDWEST POWER	DATE	03/24/20
CONTROL NUMBER	BHC74-87M	DATE	03/24/20
CONTROL NUMBER	MINNEAPOLIS, MINNESOTA	DATE	03/24/20
CONTROL NUMBER	PHONE (763) 551-1555 FAX: (763) 551-5275	DATE	03/24/20
CONTROL NUMBER		DATE	03/24/20

NOTES:


1. USE THIS CABINET FOR CT METERING
2. WREA WILL PROVIDE CT'S. MEMBER/CONTRACTOR SHALL INSTALL
3. MEMBER TO SUPPLY CT CABINET

ITEM	QTY.	PART NUMBER	DESCRIPTION
1	1	1167973	SHELL WELDMENT
2	1	1028222	CLOSING PLATE ASSY
3	1	1153700	BRIDGE
4	1	1026536	NO BYPASS BLOCK ASSY.
5	1	1138903	4 POS. TERM. CONN.
6	1	1159186	T/S BRIDGE
7	1	1153698	FRONT ASSY.
8	4	1025353	SCREW 10-32 x 1
9	8	1000183	SCREW 12-24 x 5/16
10	2	1022084	SCREW 8-32 x 3/4
11	2	1001331	SHW-SC 10-32 .5 SR ST
12	1	N/A	STAMP CAT. NO.
13	1	1000044	LABEL HUB OPENING
14	1	1153701	LABEL, INSTRUMENT TRANSFORMER
15	1	1000664	LABEL, DANGER
16	1	1000158	PAID WIREMAN, 8.37 x 7.50
17	2	1212980	RISER ASSY 4.78 HEIGHT
18	1	1172462	CUTTER 1-PER (NOT SHOWN)



PRODUCTION NOTES:

- 1) SCREW 1022084 TO BE INSTALLED FINGER TIGHT ONLY IF TERMINAL STRIP NOT INSTALLED.
- 2) SCREW001311 TO BE INSTALLED FINGER TIGHT ONLY.
- 3) INSTALL PLASTIC BACKER STRIP TIED TO TERMINAL CONNECTOR WHICH IS SUPPLIED WITH WIRING HARNESS.
- 4) WHEN WIRING HARNESS IS USED, THE WIRES ARE ROUTED INTO THE TOP OF THE 4 POS. TERM. CONNECTOR.



SUFFIX	CUSTOMER	#138903 TERM. QTY.
-NTS	WEST RIVER ELECTRIC	0
-STRIP	TWO SOCKETS TWO METER	1

[illegible]


REV.	DATE	DESCRIPTION	BY	ECO No.
B	9-1-16	AUDIT NOTE #3, REMOVE 118923.	KSP	034770
C1	09/16/17	AUDIT NOTE 4, CORRECT KIL AND INTG. EXCESS QTY, UPDATE DRAWING TO STANDARD	BU	034974
C2	9/17/19	AUDIT DISPO 124000 (2), SPECX 100002 (8), WAS (4)	FOA	043441

NOTES:

1. WREA WILL PROVIDE METER CAN TO MEMBER/CONTRACTOR AT SPECIFIED COST

WREA APPROVED METER CAN
METER REQUIREMENTS





1	CHG TS TO TIN, NO COVER	4/23/2020
REV	DESCRIPTION	DATE
	<div><div>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE: FRACTIONS DECIMALS ANGLES ±.0000 ±.0005 ±.0010 ±.0015 ±.0020 ±.0025 ±.0030 ±.0040 ±.0050 ±.0060 ±.0070 ±.0080 ±.0090 ±.0100 ±.0125 ±.0150 ±.0175 ±.0200 ±.0250 ±.0300 ±.0350 ±.0400 ±.0500 ±.0600 ±.0700 ±.0800 ±.1000 ±.1250 ±.1500 ±.1600 ±.1800 ±.2000 ±.2500 ±.3000 ±.3500 ±.4000 ±.4500 ±.5000 ±.5500 ±.6000 ±.6500 ±.7000 ±.7500 ±.8000 ±.8500 ±.9000 ±.9500 ±.1000 ±.1050 ±.1100 ±.1150 ±.1200 ±.1250 ±.1300 ±.1350 ±.1400 ±.1450 ±.1500 ±.1550 ±.1600 ±.1650 ±.1700 ±.1750 ±.1800 ±.1850 ±.1900 ±.1950 ±.2000 ±.2050 ±.2100 ±.2150 ±.2200 ±.2250 ±.2300 ±.2350 ±.2400 ±.2450 ±.2500 ±.2550 ±.2600 ±.2650 ±.2700 ±.2750 ±.2800 ±.2850 ±.2900 ±.2950 ±.3000 ±.3050 ±.3100 ±.3150 ±.3200 ±.3250 ±.3300 ±.3350 ±.3400 ±.3450 ±.3500 ±.3550 ±.3600 ±.3650 ±.3700 ±.3750 ±.3800 ±.3850 ±.3900 ±.3950 ±.4000 ±.4050 ±.4100 ±.4150 ±.4200 ±.4250 ±.4300 ±.4350 ±.4400 ±.4450 ±.4500 ±.4550 ±.4600 ±.4650 ±.4700 ±.4750 ±.4800 ±.4850 ±.4900 ±.4950 ±.5000 ±.5050 ±.5100 ±.5150 ±.5200 ±.5250 ±.5300 ±.5350 ±.5400 ±.5450 ±.5500 ±.5550 ±.5600 ±.5650 ±.5700 ±.5750 ±.5800 ±.5850 ±.5900 ±.5950 ±.6000 ±.6050 ±.6100 ±.6150 ±.6200 ±.6250 ±.6300 ±.6350 ±.6400 ±.6450 ±.6500 ±.6550 ±.6600 ±.6650 ±.6700 ±.6750 ±.6800 ±.6850 ±.6900 ±.6950 ±.7000 ±.7050 ±.7100 ±.7150 ±.7200 ±.7250 ±.7300 ±.7350 ±.7400 ±.7450 ±.7500 ±.7550 ±.7600 ±.7650 ±.7700 ±.7750 ±.7800 ±.7850 ±.7900 ±.7950 ±.8000 ±.8050 ±.8100 ±.8150 ±.8200 ±.8250 ±.8300 ±.8350 ±.8400 ±.8450 ±.8500 ±.8550 ±.8600 ±.8650 ±.8700 ±.8750 ±.8800 ±.8850 ±.8900 ±.8950 ±.9000 ±.9050 ±.9100 ±.9150 ±.9200 ±.9250 ±.9300 ±.9350 ±.9400 ±.9450 ±.9500 ±.9550 ±.9600 ±.9650 ±.9700 ±.9750 ±.9800 ±.9850 ±.9900 ±.9950 ±.1000 ±.1005 ±.1010 ±.1015 ±.1020 ±.1025 ±.1030 ±.1035 ±.1040 ±.1045 ±.1050 ±.1055 ±.1060 ±.1065 ±.1070 ±.1075 ±.1080 ±.1085 ±.1090 ±.1095 ±.1100 ±.1105 ±.1110 ±.1115 ±.1120 ±.1125 ±.1130 ±.1135 ±.1140 ±.1145 ±.1150 ±.1155 ±.1160 ±.1165 ±.1170 ±.1175 ±.1180 ±.1185 ±.1190 ±.1195 ±.1200 ±.1205 ±.1210 ±.1215 ±.1220 ±.1225 ±.1230 ±.1235 ±.1240 ±.1245 ±.1250 ±.1255 ±.1260 ±.1265 ±.1270 ±.1275 ±.1280 ±.1285 ±.1290 ±.1295 ±.1300 ±.1305 ±.1310 ±.1315 ±.1320 ±.1325 ±.1330 ±.1335 ±.1340 ±.1345 ±.1350 ±.1355 ±.1360 ±.1365 ±.1370 ±.1375 ±.1380 ±.1385 ±.1390 ±.1395 ±.1400 ±.1405 ±.1410 ±.1415 ±.1420 ±.1425 ±.1430 ±.1435 ±.1440 ±.1445 ±.1450 ±.1455 ±.1460 ±.1465 ±.1470 ±.1475 ±.1480 ±.1485 ±.1490 ±.1495 ±.1500 ±.1505 ±.1510 ±.1515 ±.1520 ±.1525 ±.1530 ±.1535 ±.1540 ±.1545 ±.1550 ±.1555 ±.1560 ±.1565 ±.1570 ±.1575 ±.1580 ±.1585 ±.1590 ±.1595 ±.1600 ±.1605 ±.1610 ±.1615 ±.1620 ±.1625 ±.1630 ±.1635 ±.1640 ±.1645 ±.1650 ±.1655 ±.1660 ±.1665 ±.1670 ±.1675 ±.1680 ±.1685 ±.1690 ±.1695 ±.1700 ±.1705 ±.1710 ±.1715 ±.1720 ±.1725 ±.1730 ±.1735 ±.1740 ±.1745 ±.1750 ±.1755 ±.1760 ±.1765 ±.1770 ±.1775 ±.1780 ±.1785 ±.1790 ±.1795 ±.1800 ±.1805 ±.1810 ±.1815 ±.1820 ±.1825 ±.1830 ±.1835 ±.1840 ±.1845 ±.1850 ±.1855 ±.1860 ±.1865 ±.1870 ±.1875 ±.1880 ±.1885 ±.1890 ±.1895 ±.1900 ±.1905 ±.1910 ±.1915 ±.1920 ±.1925 ±.1930 ±.1935 ±.1940 ±.1945 ±.1950 ±.1955 ±.1960 ±.1965 ±.1970 ±.1975 ±.1980 ±.1985 ±.1990 ±.1995 ±.2000 ±.2005 ±.2010 ±.2015 ±.2020 ±.2025 ±.2030 ±.2035 ±.2040 ±.2045 ±.2050 ±.2055 ±.2060 ±.2065 ±.2070 ±.2075 ±.2080 ±.2085 ±.2090 ±.2095 ±.2100 ±.2105 ±.2110 ±.2115 ±.2120 ±.2125 ±.2130 ±.2135 ±.2140 ±.2145 ±.2150 ±.2155 ±.2160 ±.2165 ±.2170 ±.2175 ±.2180 ±.2185 ±.2190 ±.2195 ±.2200 ±.2205 ±.2210 ±.2215 ±.2220 ±.2225 ±.2230 ±.2235 ±.2240 ±.2245 ±.2250 ±.2255 ±.2260 ±.2265 ±.2270 ±.2275 ±.2280 ±.2285 ±.2290 ±.2295 ±.2300 ±.2305 ±.2310 ±.2315 ±.2320 ±.2325 ±.2330 ±.2335 ±.2340 ±.2345 ±.2350 ±.2355 ±.2360 ±.2365 ±.2370 ±.2375 ±.2380 ±.2385 ±.2390 ±.2395 ±.2400 ±.2405 ±.2410 ±.2415 ±.2420 ±.2425 ±.2430 ±.2435 ±.2440 ±.2445 ±.2450 ±.2455 ±.2460 ±.2465 ±.2470 ±.2475 ±.2480 ±.2485 ±.2490 ±.2495 ±.2500 ±.2505 ±.2510 ±.2515 ±.2520 ±.2525 ±.2530 ±.2535 ±.2540 ±.2545 ±.2550 ±.2555 ±.2560 ±.2565 ±.2570 ±.2575 ±.2580 ±.2585 ±.2590 ±.2595 ±.2600 ±.2605 ±.2610 ±.2615 ±.2620 ±.2625 ±.2630 ±.2635 ±.2640 ±.2645 ±.2650 ±.2655 ±.2660 ±.2665 ±.2670 ±.2675 ±.2680 ±.2685 ±.2690 ±.2695 ±.2700 ±.2705 ±.2710 ±.2715 ±.2720 ±.2725 ±.2730 ±.2735 ±.2740 ±.2745 ±.2750 ±.2755 ±.2760 ±.2765 ±.2770 ±.2775 ±.2780 ±.2785 ±.2790 ±.2795 ±.2800 ±.2805 ±.2810 ±.2815 ±.2820 ±.2825 ±.2830 ±.2835 ±.2840 ±.2845 ±.2850 ±.2855 ±.2860 ±.2865 ±.2870 ±.2875 ±.2880 ±.2885 ±.2890 ±.2895 ±.2900 ±.2905 ±.2910 ±.2915 ±.2920 ±.2925 ±.2930 ±.2935 ±.2940 ±.2945 ±.2950 ±.2955 ±.2960 ±.2965 ±.2970 ±.2975 ±.2980 ±.2985 ±.2990 ±.2995 ±.3000 ±.3005 ±.3010 ±.3015 ±.3020 ±.3025 ±.3030 ±.3035 ±.3040 ±.3045 ±.3050 ±.3055 ±.3060 ±.3065 ±.3070 ±.3075 ±.3080 ±.3085 ±.3090 ±.3095 ±.3100 ±.3105 ±.3110 ±.3115 ±.3120 ±.3125 ±.3130 ±.3135 ±.3140 ±.3145 ±.3150 ±.3155 ±.3160 ±.3165 ±.3170 ±.3175 ±.3180 ±.3185 ±.3190 ±.3195 ±.3200 ±.3205 ±.3210 ±.3215 ±.3220 ±.3225 ±.3230 ±.3235 ±.3240 ±.3245 ±.3250 ±.3255 ±.3260 ±.3265 ±.3270 ±.3275 ±.3280 ±.3285 ±.3290 ±.3295 ±.3300 ±.3305 ±.3310 ±.3315 ±.3320 ±.3325 ±.3330 ±.3335 ±.3340 ±.3345 ±.3350 ±.3355 ±.3360 ±.3365 ±.3370 ±.3375 ±.3380 ±.3385 ±.3390 ±.3395 ±.3400 ±.3405 ±.3410 ±.3415 ±.3420 ±.3425 ±.3430 ±.3435 ±.3440 ±.3445 ±.3450 ±.3455 ±.3460 ±.3465 ±.3470 ±.3475 ±.3480 ±.3485 ±.3490 ±.3495 ±.3500 ±.3505 ±.3510 ±.3515 ±.3520 ±.3525 ±.3530 ±.3535 ±.3540 ±.3545 ±.3550 ±.3555 ±.3560 ±.3565 ±.3570 ±.3575 ±.3580 ±.3585 ±.3590 ±.3595 ±.3600 ±.3605 ±.3610 ±.3615 ±.3620 ±.3625 ±.3630 ±.3635 ±.3640 ±.3645 ±.3650 ±.3655 ±.3660 ±.3665 ±.3670 ±.3675 ±.3680 ±.3685 ±.3690 ±.3695 ±.3700 ±.3705 ±.3710 ±.3715 ±.3720 ±.3725 ±.3730 ±.3735 ±.3740 ±.3745 ±.3750 ±.3755 ±.3760 ±.3765 ±.3770 ±.3775 ±.3780 ±.3785 ±.3790 ±.3795 ±.3800 ±.3805 ±.3810 ±.3815 ±.3820 ±.3825 ±.3830 ±.3835 ±.3840 ±.3845 ±.3850 ±.3855 ±.3860 ±.3865 ±.3870 ±.3875 ±.3880 ±.3885 ±.3890 ±.3895 ±.3900 ±.3905 ±.3910 ±.3915 ±.3920 ±.3925 ±.3930 ±.3935 ±.3940 ±.3945 ±.3950 ±.3955 ±.3960 ±.3965 ±.3970 ±.3975 ±.3980 ±.3985 ±.3990 ±.3995 ±.4000 ±.4005 ±.4010 ±.4015 ±.4020 ±.4025 ±.4030 ±.4035 ±.4040 ±.4045 ±.4050 ±.4055 ±.4060 ±.4065 ±.4070 ±.4075 ±.4080 ±.4085 ±.4090 ±.4095 ±.4100 ±.4105 ±.4110 ±.4115 ±.4120 ±.4125 ±.4130 ±.4135 ±.4140 ±.4145 ±.4150 ±.4155 ±.4160 ±.4165 ±.4170 ±.4175 ±.4180 ±.4185 ±.4190 ±.4195 ±.4200 ±.4205 ±.4210 ±.4215 ±.4220 ±.4225 ±.4230 ±.4235 ±.4240 ±.4245 ±.4250 ±.4255 ±.4260 ±.4265 ±.4270 ±.4275 ±.4280 ±.4285 ±.4290 ±.4295 ±.4300 ±.4305 ±.4310 ±.4315 ±.4320 ±.4325 ±.4330 ±.4335 ±.4340 ±.4345 ±.4350 ±.4355 ±.4360 ±.4365 ±.4370 ±.4375 ±.4380 ±.4385 ±.4390 ±.4395 ±.4400 ±.4405 ±.4410 ±.4415 ±.4420 ±.4425 ±.4430 ±.4435 ±.4440 ±.4445 ±.4450 ±.4455 ±.4460 ±.4465 ±.4470 ±.4475 ±.4480 ±.4485 ±.4490 ±.4495 ±.4500 ±.4505 ±.4510 ±.4515 ±.4520 ±.4525 ±.4530 ±.4535 ±.4540 ±.4545 ±.4550 ±.4555 ±.4560 ±.4565 ±.4570 ±.4575 ±.4580 ±.4585 ±.4590 ±.4595 ±.4600 ±.4605 ±.4610 ±.4615 ±.4620 ±.4625 ±.4630 ±.4635 ±.4640 ±.4645 ±.4650 ±.4655 ±.4660 ±.4665 ±.4670 ±.4675 ±.4680 ±.4685 ±.4690 ±.4695 ±.4700 ±.4705 ±.4710 ±.4715 ±.4720 ±.4725 ±.4730 ±.4735 ±.4740 ±.4745 ±.4750 ±.4755 ±.4760 ±.4765 ±.4770 ±.4775 ±.4780 ±.4785 ±.4790 ±.4795 ±.4800 ±.4805 ±.4810 ±.4815 ±.4820 ±.4825 ±.4830 ±.4835 ±.4840 ±.4845 ±.4850 ±.4855 ±.4860 ±.4865 ±.4870 ±.4875 ±.4880 ±.4885 ±.4890 ±.4895 ±.4900 ±.4905 ±.4910 ±.4915 ±.4920 ±.4925 ±.4930 ±.4935 ±.4940 ±.4945 ±.4950 ±.4955 ±.4960 ±.4965 ±.4970 ±.4975 ±.4980 ±.4985 ±.4990 ±.4995 ±.5000 ±.5005 ±.5010 ±.5015 ±.5020 ±.5025 ±.5030 ±.5035 ±.5040 ±.5045 ±.5050 ±.5055 ±.5060 ±.5065 ±.5070 ±.5075 ±.5080 ±.5085 ±.5090 ±.5095 ±.5100 ±.5105 ±.5110 ±.5115 ±.5120 ±.5125 ±.5130 ±.5135 ±.5140 ±.5145 ±.5150 ±.5155 ±.5160 ±.5165 ±.5170 ±.5175 ±.5180 ±.5185 ±.5190 ±.5195 ±.5200 ±.5205 ±.5210 ±.5215 ±.5220 ±.5225 ±.5230 ±.5235 ±.5240 ±.5245 ±.5250 ±.5255 ±.5260 ±.5265 ±.5270 ±.5275 ±.5280 ±.5285 ±.5290 ±.5295 ±.5300 ±.5305 ±.5310 ±.5315 ±.5320 ±.5325 ±.5330 ±.5335 ±.5340 ±.5345 ±.5350 ±.5355 ±.5360 ±.5365 ±.5370 ±.5375 ±.5380 ±.5385 ±.5390 ±.5395 ±.5400 ±.5405 ±.5410 ±.5415 ±.5420 ±.5425 ±.5430 ±.5435 ±.5440 ±.5445 ±.5450 ±.5455 ±.5460 ±.5465 ±.5470 ±.5475 ±.5480 ±.5485 ±.5490 ±.5495 ±.5500 ±.5505 ±.5510 ±.5515 ±.5520 ±.5525 ±.5530 ±.5535 ±.5540 ±.5545 ±.5550 ±.5555 ±.5560 ±.5565 ±.5570 ±.5575 ±.5580 ±.5585 ±.5590 ±.5595 ±.5600 ±.5605 ±.5610 ±.5615 ±.5620 ±.5625 ±.5630 ±.5635 ±.5640 ±.5645 ±.5650 ±.5655 ±.5660 ±.5665 ±.5670 ±.5675 ±.5680 ±.5685 ±.5690 ±.5695 ±.5700 ±.5705 ±.5710 ±.5715 ±.5720 ±.5725 ±.5730 ±.5735 ±.5740 ±.5745 ±.5750 ±.5755 ±.5760 ±.5765 ±.5770 ±.5775 ±.5780 ±.5785 ±.5790 ±.5795 ±.5800 ±.5805 ±.5810 ±.5815 ±.5820 ±.5825 ±.5830 ±.5835 ±.5840 ±.5845 ±.5850 ±.5855 ±.5860 ±.5865 ±.5870 ±.5875 ±.5880 ±.5885 ±.5890 ±.5895 ±.5900 ±.5905 ±.5910 ±.5915 ±.5920 ±.5925 ±.5930 ±.5935 ±.5940 ±.5945 ±.5950 ±.5955 ±.5960 ±.5965 ±.5970 ±.5975 ±.5980 ±.5985 ±.5990 ±.5995 ±.6000 ±.6005 ±.6010 ±.6015 ±.6020 ±.6025 ±.6030 ±.6035 ±.6040 ±.6045 ±.6050 ±.6055 ±.6060 ±.6065 ±.6070 ±.6075 ±.6080 ±.6085 ±.6090 ±.6095 ±.6100 ±.6105 ±.6110 ±.6115 ±.6120 ±.6125 ±.6130 ±.6135 ±.6140 ±.6145 ±.6150 ±.6155 ±.6160 ±.6165 ±.6170 ±.6175 ±.6180 ±.6185 ±.6190 ±.6195 ±.6200 ±.6205 ±.6210 ±.6215 ±.6220 ±.6225 ±.6230 ±.6235 ±.6240 ±.6245 ±.6250 ±.6255 ±.6260 ±.6265 ±.6270 ±.6275 ±.6280 ±.6285 ±.6290 ±.6295 ±.6300 ±.6305 ±.6310 ±.6315 ±.6320 ±.6325 ±.6330 ±.6335 ±.6340 ±.6345 ±.6350 ±.6355 ±.6360 ±.6365 ±.6370 ±.6375 ±.6380 ±.6385 ±.6390 ±.6395 ±.6400 ±.6405 ±.6410 ±.6415 ±.6420 ±.6425 ±.6430 ±.6435 ±.6440 ±.6445 ±.6450 ±.6455 ±.6460 ±.6465 ±.6470 ±.6475 ±.6480 ±.6485 ±.6490 ±.6495 ±.6500 ±.6505 ±.6510 ±.6515 ±.6520 ±.6525 ±.6530 ±.6535 ±.6540 ±.6545 ±.6550 ±.6555 ±.6560 ±.6565 ±.6570 ±.6575 ±.6580 ±.6585 ±.6590 ±.6595 ±.6600 ±.6605 ±.6610 ±.6615 ±.6620 ±.6625 ±.6630 ±.6635 ±.6640 ±.6645 ±.6650 ±.6655 ±.6660 ±.6665 ±.6670 ±.6675 ±.6680 ±.6685 ±.6690 ±.6695 ±.6700 ±.6705 ±.6710 ±.6715 ±.6720 ±.6725 ±.6730 ±.6735 ±.6740 ±.6745 ±.6750 ±.6755 ±.6760 ±.6765 ±.6770 ±.6775 ±.6780 ±.6785 ±.6790 ±.6795 ±.6800 ±.6805 ±.6810 ±.6815 ±.6820 ±.6825 ±.6830 ±.6835 ±.6840 ±.6845 ±.6850 ±.6855 ±.6860 ±.6865 ±.6870 ±.6875 ±.6880 ±.6885 ±.6890 ±.6895 ±.6900 ±.6905 ±.6910 ±.6915 ±.6920 ±.6925 ±.6930 ±.6935 ±.6940 ±.6945 ±.6950 ±.6955 ±.6960 ±.6965 ±.6970 ±.6975 ±.6980 ±.6985 ±.6990 ±.6995 ±.7000 ±.7005 ±.7010 ±.7015 ±.7020 ±.7025 ±.7030 ±.7035 ±.7040 ±.7045 ±.7050 ±.7055 ±.7060 ±.7065 ±.7070 ±.7075 ±.7080 ±.7085 ±.7090 ±.7095 ±.7100 ±.7105 ±.7110 ±.7115 ±.7120 ±.7125 ±.7130 ±.7135 ±.7140 ±.7145 ±.7150 ±.7155 ±.7160 ±.7165 ±.7170 ±.7175 ±.7180 ±.7185 ±.7190 ±.7195 ±.7200 ±.7205 ±.7210 ±.7215 ±.7220 ±.7225 ±.7230 ±.7235 ±.7240 ±.7245 ±.7250 ±.7255 ±.7260 ±.7265 ±.7270 ±.7275 ±.7280 ±.7285 ±.7290 ±.7295 ±.7300 ±.7305 ±.7310 ±.7315 ±.7320 ±.7325 ±.7330 ±.7335 ±.7340 ±.7345 ±.7350 ±.7355 ±.7360 ±.7365 ±.7370 ±.7375 ±.7380 ±.7385 ±.7390 ±.7395 ±.7400 ±.7405 ±.7410 ±.7415 ±.7420 ±.7425 ±.7430 ±.7435 ±.7440 ±.7445 ±.7450 ±.7455 ±.7460 ±.7465 ±.7470 ±.7475 ±.7480 ±.7485 ±.7490 ±.7495 ±.7500 ±.7505 ±.7510 ±.7515 ±.7520 ±.7525 ±.7530 ±.7535 ±.7540 ±.7545 ±.7550 ±.7555 ±.7560 ±.7565 ±.7570 ±.7575 ±.7580 ±.7585 ±.7590 ±.7595 ±.7600 ±.7605 ±.7610 ±.7615 ±.7620 ±.7625 ±.7630 ±.7635 ±.7640 ±.7645 ±.7650 ±.7655 ±.7660 ±.7665 ±.7670 ±.7675 ±.7680 ±.7685 ±.7690 ±.7695 ±.7700 ±.7705 ±.7710 ±.7715 ±.7720 ±.7725 ±.7730 ±.7735 ±.7740 ±.7745 ±.7750 ±.7755 ±.7760 ±.7765 ±.7770 ±.7775 ±.7780 ±.7785 ±.7790 ±.7795 ±.7800 ±.7805 ±.7810 ±.7815 ±.7820 ±.7825 ±.7830 ±.7835 ±.7840 ±.7845 ±.7850 ±.7855 ±.7860 ±.7865 ±.7870 ±.7875 ±.7880 ±.7885 ±.7890 ±.7895 ±.7900 ±.7905 ±.7910 ±.7915 ±.7920 ±.7925 ±.7930 ±.7935 ±.7940 ±.7945 ±.7950 ±.7955 ±.7960 ±.7965 ±.7970 ±.7975 ±.7980 ±.7985 ±.7990 ±.7995 ±.8000 ±.8005 ±.8010 ±.8015 ±.8020 ±.8025 ±.8030 ±.8035 ±.8040 ±.8045 ±.8050 ±.8055 ±.8060 ±.8065 ±.8070 ±.8075 ±.8080 ±.8085 ±.8090 ±.8095 ±.8100 ±.8105 ±.8110 ±.8115 ±.8120 ±.8125 ±.8130 ±.8135 ±.8140 ±.8145 ±.8150 ±.8155 ±.8160 ±.8165 ±.8170 ±.8175 ±.8180 ±.8185 ±.8190 ±.8195 ±.8200 ±.8205 ±.8210 ±.8215 ±.8220 ±.8225 ±.8230 ±.8235 ±.8240 ±.8245 ±.8250 ±.8255 ±.8260 ±.8265 ±.8270 ±.8275 ±.8280 ±.8285 ±.8290 ±.8295 ±.8300 ±.8305 ±.8310 ±.8315 ±.8320 ±.8325 ±.8330 ±.8335 ±.8340 ±.8345 ±.8350 ±.8355 ±.8360 ±.8365 ±.8370 ±.8375 ±.8380 ±.8385 ±.8390 ±.8395 ±.8400 ±.8405 ±.8410 ±.8415 ±.8420 ±.8425 ±.8430 ±.8435 ±.8440 ±.8445 ±.8450 ±.8455 ±.8460 ±.8465 ±.8470 ±.8475 ±.8480 ±.8485 ±.8490 ±.8495 ±.8500 ±.8505 ±.8510 ±.8515 ±.8520 ±.8525 ±.8530 ±.8535 ±.8540 ±.8545 ±.8550 ±.8555 ±.8560 ±.8565 ±.8570 ±.8575 ±.8580 ±.8585 ±.8590 ±.8595 ±.8600 ±.8605 ±.8610 ±.8615 ±.8620 ±.8625 ±.8630 ±.8635 ±.8640 ±.8645 ±.8650 ±.8655 ±.8660 ±.8665 ±.8670 ±.8675 ±.8680 ±.8685 ±.8690 ±.8695 ±.8700 ±.8705 ±.8710 ±.8715 ±.8720 ±.8725 ±.8730 ±.8735 ±.8740 ±.8745 ±.8750 ±.8755 ±.8760 ±.8765 ±.8770 ±.8775 ±.8780 ±.8785 ±.8790 ±.8795 ±.8800 ±.8805 ±.8810 ±.8815 ±.8820 ±.8825 ±.8830 ±.8835 ±.8840 ±.8845 ±.8850 ±.8855 ±.8860 ±.8865 ±.8870 ±.8875 ±.8880 ±.8885 ±.8890 ±.8895 ±.8900 ±.8905 ±.8910 ±.8915 ±.8920 ±.8925 ±.8930 ±.8935 ±.8940 ±.8945 ±.8950 ±.8955 ±.8960 ±.8965 ±.8970 ±.8975 ±.8980 ±.8985 ±.8990 ±.8995 ±.9000 ±.9005 ±.9010 ±.9015 ±.9020 ±.9025 ±.9030 ±.9035 ±.9040 ±.9045 ±.9050 ±.9055 ±.9060 ±.9065 ±.9070 ±.9075 ±.9080 ±.9085 ±.9090 ±.9095 ±.9100 ±.9105 ±.9110 ±.9115 ±.9120 ±.9125 ±.9130 ±.9135 ±.9140 ±.9145 ±.9150 ±.9155 ±.9160 ±.9165 ±.9170 ±.9175 ±.9180 ±.9185 ±.9190 ±.9195 ±.9200 ±.9205 ±.9210 ±.9215 ±.9220 ±.9225 ±.9230 ±.9235 ±.9240 ±.9245 ±.9250 ±.9255 ±.9260 ±.9265 ±.9270 ±.9275 ±.9280 ±.9285 ±.9290 ±.9295 ±.9300 ±.9305</div></div>	

PROPRIETARY STATEMENT

This drawing is the PROPERTY of Brooks Utility Products, Inc., a subsidiary of the Tyden Brooks Company. This drawing contains PROPRIETARY and CONFIDENTIAL information and is a TRADE SECRET pursuant to Michigan Law. This drawing is loaned to you upon condition that it not be reproduced or copied in any manner, in whole or in part, or used for furnishing information to others for any purpose. This drawing is to be returned upon request.


NOTES:

1. WREA WILL PROVIDE METER CAN TO MEMBER/CONTRACTOR AT SPECIFIED COST


CT METER CAN WITH TEST SWITCHES METER REQUIREMENTS



PLAN VIEW



SECTION VIEW



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. TRENCH REQUIREMENTS
10. Member/Contractor shall achieve 95% compaction in and around pad to avoid settling. Consult project geotechnical evaluation for procedures and recommendations to achieve proper compaction.
11. If geotechnical evaluation is not available, Member/Contractor shall use compaction methods to ensure the pad does not settle. Using compaction machinery, loose lifts no greater than 3", and proper moisture levels should provide acceptable results.
12. 95% compacted fill
13. 8" compacted base course 12" wide around the edge of pad
14. 4" sand
15. Undisturbed soils
16. 3" to 15" of pad exposed depending on size of pad (consult with WREA for specific elevation above final grade)

DESIGN: SRB

DRAWING: SRB

APPROVED BY: SRB
DATE: 02-20

TYPICAL BASEMENT INSTALLATION PAD REQUIREMENTS



REV. DATE: 02-20
REV. NO.: 1

DRAWING NUMBER
PAD-1

PERMANENT SERVICE REQUIREMENTS

1. Checklist in this booklet completed
2. Member/Contractor is urged to make early contact with WREA for permanent service.
3. WREA will connect the service after copy of the State wiring certificate and/or City inspection is on file.
4. Permanent service location shall be determined and approved by WREA staking personnel and will vary depending on multiple factors.
5. Permanent service shall be located where the meter will be protected from damage.
6. Equipment shall be located according to clearance requirements found in this booklet. Should relocation be necessary, the cost shall be the responsibility of the Member/Contractor.
7. Member/Contractor owned metering equipment, switching devices, conduits, conductors, luminaries, etc. shall not be mounted to WREA poles.
8. Three phase services will, at the option of WREA, be CT metered provided by Contractor/Member.
9. Overhead permanent services shall be supported on a WREA approved pole, wall, or structure. The maximum service drop length from WREA's pole to the service will be dependent upon conductor size. Consult WREA's staking department to determine the maximum distance.
10. Standard voltage is 120/240V for single phase and 120/208V or 277/480V for three phase.
11. No delta connected three phase services are allowed
12. For the following drawings, a number in a bubble "##" references to the note at the bottom of the page.

DESIGN: M.S.

DRAWING: A.K.

APPROVED BY: M.S.
DATE: 1/2007

REQUIREMENTS PERMANENT SERVICE REQUIREMENTS




**West River Electric
Association, Inc.**

Your Touchstone Energy® Cooperative

REV. DATE: 02-20
REV. NO.: 3

DRAWING NUMBER
PERM-1



NOTES:

(NOT TO SCALE)


1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
 - d. TRENCH REQUIREMENTS
10. If paved area is adjacent to building foundation, the conduit must be installed beyond the pavement. All elbows shall be long sweep variety.
11. WREA will flag route for secondary trenching for Member/Contractor to provide.
12. Adequate framing for anchoring meter can to structure. Minimum 2 horizontal 2x4 blocks installed behind sheathing as shown.
13. Connection to Member/Contractor panel from bottom lugs in the meter can
14. Underground service line shall be backfilled before energizing service
20. WREA will furnish/install:
 - a. Meter
 - b. Secondary wire from WREA transformer to meter
30. Member/Contractor shall furnish/install
 - a. Meter can and mounting
 - b. Grounding per the NEC
 - c. All service conduit 2" minimum schedule 80
 - d. Trench, clean backfill, and conduit as explained in this booklet

DESIGN: M.S.
DRAWING: A.K.
APPROVED BY: M.S.
DATE: 1/2007

320 AMP UNDERGROUND
PERMANENT SERVICE



REV. DATE: 02-20
REV. NO.: 4
DRAWING NUMBER: PERM-2



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
10. Cable drip loop must be at least 18" above roof when installed above an overhang roof penetration. Conductors shall not exceed 6' in length and 4' horizontally past the overhang per the NEC
11. Adequate framing for anchoring meter can to structure. Minimum 2 horizontal 2x4 blocks installed behind sheathing as shown.
12. Connection to Member/Contractor panel from bottom lugs in the meter can
13. Member/Contractor to provide 2" rigid galvanized steel conduit attachment of adequate strength below weatherhead and directly above hub identified for service entrance equipment with no conduit couplings per the NEC.
20. WREA will furnish/install:
 - a. Meter
 - b. Secondary wire from WREA transformer to meter
30. Member/Contractor shall furnish/install
 - a. Meter can and mounting
 - b. Weatherhead
 - c. All 2" steel service entrance conduit 2"
 - d. Wire in conduit with 18" of length outside of weatherhead
 - e. Grounding per the NEC

DESIGN: M.S.

DRAWING: A.K.


APPROVED BY: M.S.
DATE: 1/2007

320 AMP OVERHEAD
PERMANENT SERVICE

 **West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE: 02-20
REV. NO.: 4

DRAWING NUMBER
PERM-3



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
10. Adequate framing for anchoring meter can to structure. Minimum 2 horizontal 2x4 blocks installed behind sheathing as shown.
11. Connection to Member/Contractor panel from bottom lugs in the meter can
12. Member/Contractor to provide insulated deadend with 1/2" eye bolt that fastens with nut and washer inside structure
13. Weatherhead must be located above and within 12" of the point of attachment to the structure per the NEC.
14. Drip loop must be installed per the NEC
20. WREA will furnish/install:
 - a. Meter
 - b. Secondary wire from WREA transformer to meter
30. Member/Contractor shall furnish/install
 - a. Meter can and mounting
 - b. Weatherhead
 - c. All 2" steel service entrance conduit 2"
 - d. Wire in conduit with 18" of length outside of weatherhead
 - e. Grounding per the NEC

DESIGN: M.S.

DRAWING: A.K.


APPROVED BY: M.S. DATE: 1/2007

320 AMP OVERHEAD TO STRUCTURE
PERMANENT SERVICE



REV. DATE: 02-20 REV. NO.: 4

DRAWING NUMBER
PERM-4



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
 - d. PAD REQUIREMENTS
 - e. TRENCH REQUIREMENTS
10. Transformer will be 75–1,500 kVA, maximum 6 connections per phase
11. Meter shall not be mounted to or in the transformer cabinet
12. Bell ends shall be installed on all conduits
13. Conduits shall extend 4" to 6" above sand inside transformer pad
14. Member/Contractor shall extend secondary wires 7' above transformer pad with a maximum of six wires per phase with maximum size of 750 kcmil copper or aluminum.
20. WREA will furnish/install:
 - a. Transformer
 - b. Primary cable to transformer
 - c. Grounding of transformer
 - d. Transformer secondary lugs
30. Member/Contractor shall furnish/install
 - a. Transformer base purchased from WREA
 - b. Trenching and backfilling
 - c. All conduits
 - d. All conductors and equipment past transformer secondaries

DESIGN: SRB

DRAWING: SRB

APPROVED BY DATE
SRB 02-20


3Ø TRANSFORMER PAD
PERMANENT SERVICE



**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE REV. NO.
06-20 2

DRAWING NUMBER
PERM-5



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
 - d. PAD REQUIREMENTS
 - e. TRENCH REQUIREMENTS
10. Transformer will be 75–1,500 kVA, maximum 6 connections per phase
11. Meter shall not be mounted to or in the transformer cabinet
12. Bell ends shall be installed on all conduits
13. Conduits shall extend 4" to 6" above sand inside transformer pad
14. Member/Contractor shall extend secondary wires 7' above transformer pad with a maximum of six wires per phase with maximum size of 750 kcmil copper or aluminum.
20. WREA will furnish/install:
 - a. Transformer
 - b. Primary cable to transformer
 - c. Grounding of transformer
 - d. Transformer secondary lugs
30. Member/Contractor shall furnish/install
 - a. Transformer and secondary cabinet base purchased from WREA
 - b. Secondary cabinet
 - c. Grounding of secondary cabinet
 - d. Trenching and backfilling
 - e. All conduits
 - f. All conductors and equipment past transformer secondaries

DESIGN: SRB

DRAWING: SRB

APPROVED BY: SRB
DATE: 02-20


3Ø TRANSFORMER WITH SECONDARY PAD
PERMANENT SERVICE



**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE: 02-20
REV. NO.: 1

DRAWING NUMBER
PERM-6



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
 - d. TRENCH REQUIREMENTS
10. WREA will flag trench route from transformer to service for member/contractor to provide.
11. Service shall be
 - a. WREA approved
 - b. Single phase 200–320 amp no ct metering
 - c. Single phase 400 amp and above ct metered
 - d. Three phase over 200 amp ct metered
 - e. Any 480V service shall be instrument rated
 - f. Commercial meters shall have mechanical bypass
12. Underground service line shall be backfilled before energizing service
13. 3" rigid galvanized pipe or 3" square tubing (1/4" min wall thickness) painted gray
20. WREA will furnish/install:
 - a. Secondary wire from WREA transformer to meter
 - b. Meter
30. Member/Contractor shall furnish/install
 - a. Meter rack and mounting
 - b. Grounding per the NEC
 - c. Trench, clean backfill, and conduit as explained in this booklet
 - d. All conduit, conductors, and equipment past meter

DESIGN: SRB

DRAWING: SRB

APPROVED BY: SRB
DATE: 02/20

STEEL POST
PERMANENT SERVICE



REV. DATE: 06-20
REV. NO.: 2

DRAWING NUMBER
PERM-7




- | | |
|--------------------|---------------|
| DESIGN: SRB | |
| DRAWING:SRB | |
| APPROVED BY
SRB | DATE
02-20 |



West River Electric Association, Inc.
Your Touchstone Energy® Cooperative

REV DATE 02-20	REV NO. 1
DRAWING NUMBER PERM-9	



NOTES:

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS

10. Locking provisions provided and utilized after energization
11. Lever operated bypass shall be installed on all commercial sockets
12. Permanently affixed identification tags shall be installed
13. Meter modules shall be approved by WREA
14. CT compartments and/or switchgear shall be approved by WREA
15. Meter modules shall be mounted between 24" and 78" to centerline from finished grade as shown above Single meter height shall be mounted per METER REQUIREMENTS drawings in this booklet.

20. WREA will furnish/install:

- a. Meters

30. Member/Contractor shall furnish/install

- a. Meter modules
- b. Meter mounting as described in PERMANENT SERVICE in this booklet
- c. Grounding per the NEC
- d. Secondary wire from WREA transformer to meter
- e. All conduit, conductors, and equipment past meter
- f. Right of way in recorded easement

DESIGN: SRB

DRAWING: SRB


APPROVED BY DATE
SRB 02-20

GANG METER MODULES
PERMANENT SERVICE



REV. DATE REV. NO.
02-20 1

DRAWING NUMBER
PERM-10



NOTES:

(NOT TO SCALE)

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
 - d. TRENCH REQUIREMENTS
10. WREA will flag trench route from transformer to service for member/contractor to provide.
11. Mobile home feeder cable shall be adequately protected and sized per the NEC.
12. Mobile home shall be located at least 5' and no more than 30' from meter pedestal per the NEC. Meter not allowed to be attached to mobile home unless prior approval from WREA.
13. Underground service line shall be backfilled before energizing service
20. WREA will:
 - a. Furnish meter pedestal
 - b. Furnish and install secondary wire from WREA transformer to meter
 - c. Furnish and install ground rod
 - d. Furnish and install meter
30. Member/Contractor shall furnish or install
 - a. Meter pedestal
 - b. Mobile home feeder cable
 - c. Trench, clean backfill, and conduit as explained in this booklet

DESIGN: SRB

DRAWING: SRB

APPROVED BY: SRB
DATE: 02/20

MOBILE HOME
PERMANENT SERVICE



**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE
02-20

REV. NO.
1

DRAWING NUMBER
PERM-11

TEMPORARY SERVICE REQUIREMENTS

1. Checklist in this booklet completed
2. Member/Contractor is urged to make early contact with WREA for temporary service.
3. WREA will connect the service after copy of the State wiring certificate and/or City inspection is on file.
4. Temporary service for construction work must be located where the meter will be protected from damage and usable throughout the construction period. Should relocation be necessary, the cost shall be the responsibility of the Member/Contractor.
5. Member/Contractor owned metering equipment, switching devices, conduits, conductors, luminaries, etc. shall not be mounted to WREA poles.
6. Standard voltage is 120/240V for single phase and 120/208V or 277/480V for three phase.
7. No delta connected three phase services are allowed
8. For the following drawings, a number in a bubble "##" references to the note at the bottom of the page.

DESIGN: M.S.

DRAWING: A.K.

APPROVED BY: M.S.
DATE: 1/2007

REQUIREMENTS TEMPORARY SERVICE



**West River Electric
Association, Inc.**


Your Touchstone Energy® Cooperative

REV. DATE
02-20

REV. NO.
4

DRAWING NUMBER

TEMP-1



NOTES:

(NOT TO SCALE)

1. The sections listed below are found in this booklet and apply to this drawing.

- a. CLEARANCE REQUIREMENTS
- b. GUARDING REQUIREMENTS
- c. METER REQUIREMENTS
- d. TRENCH REQUIREMENTS

10. Pressure treated 4x6 wood post and installed as shown above

11. Post conduit 2\" PVC and installed as shown above

12. WREA will flag trench route from transformer to service for Member/Contractor to provide.

13. Underground service line shall be backfilled before energizing service

14. All underground temporary meter loops shall be located at the transformer or secondary service wire on the lot line.

15. Free standing pedestal must be adequately braced and anchored with minimum 4x4 post. This pedestal will be used with pad mount transformer.

16. Qty. 4 #6 minimum conductors installed in 1-1/2\" liquid tight flexible conduit. 8' min. and 12' max. length between meter and transformer

17. 48\" conductor tails left for pad mount transformer or secondary junction box connections by WREA.

20. WREA will furnish/install:

- a. Meter
- b. Transformer or secondary junction box connection, no secondary conductors

30. Member/Contractor shall furnish/install

- a. Meter pedestal
- b. Meter mounting
- c. Grounding per the NEC
- d. Secondary wire from WREA transformer or secondary junction box to meter
- e. Trench, clean backfill, and conduit as explained in this booklet

DESIGN: M.S.

DRAWING: A.K.

APPROVED BY DATE
M.S. 1/2007

UNDERGROUND METER MOUNTING TEMPORARY SERVICE




**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE
02-2019

REV. NO.
3

DRAWING NUMBER
TEMP-2



NOTES:

(NOT TO SCALE)

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. CLEARANCE REQUIREMENTS
 - b. GUARDING REQUIREMENTS
 - c. METER REQUIREMENTS
10. Overhead temporary service drop shall be supported on a WREA approved pole or timber.
11. The maximum service drop length from a WREA pole to the service is designed and approved by WREA staking personnel.
12. Guying design to be designed and approved by WREA staking personnel.
20. WREA will furnish/install:
 - a. Meter
 - b. Transformer connection, no secondary conductors
30. Member/Contractor shall furnish/install
 - a. Meter pedestal
 - b. Meter mounting pole or timber
 - c. Grounding per the NEC
 - d. Secondary wire from WREA transformer to meter
 - e. Trench, clean backfill, and conduit as explained in this booklet

DESIGN: M.S.
DRAWING: A.K.
APPROVED BY: M.S. DATE: 1/2007

OVERHEAD METER MOUNTING
TEMPORARY SERVICE



REV. DATE: 02-20 REV. NO.: 4

DRAWING NUMBER
TEMP-3

DEFINITIONS:

Electric Utilities:

Power, lighting, telephone, cable t.v., signal circuits, etc...

Non-electric Utilities:

Water, gas, sewer, storm drains, etc...

Approved Conduit Bedding Material:

4" of sand, fines, or clean dirt around each conduit free of rocks with proper moisture levels

Approved Conduit:

- a. HDPE black endless with 3 red stipes
- b. PVC
 - Schedule 40 for under open ground
 - Schedule 80 for under roadways
- c. SIZE
 - 3" for residential services
 - 6" for three phase services
- d. Bends
 - Primary conduit to use fiberglass 48" sweeps on all corners
 - Residential to use fiberglass 24" radius sweeps on all corners if length exceeds 150'
 - Maximum of 270° of turns (e.g. three right turns)
- d. Length
 - Residential secondary maximum length of 250'

Approved Pull Tape:

Minimum 1/2" width, 1,200lb in strength

Adequate Trench Compaction:

Follow project geotechnical evaluation for procedures and recommendations to achieve proper compaction to avoid settling. If geotechnical evaluation is not available, Member/Contractor shall use compaction methods to ensure the trench does not settle. Using compaction machinery, loose lifts no greater than 6", and proper moisture levels should provide acceptable results.

NOTES:

1. Member/Contractor shall follow all trenching and excavation local, state, and federal OSHA regulations regarding safe work practices.
2. Before digging, Member/Contractor shall locate underground utilities and verify clearances by contacting One Call of South Dakota at 811 or 1-800-781-7474 if calling from out of state.
3. WREA will flag all trench routes to be followed before excavation.
4. Secondary trench shall run at a right angle from the meter socket for at least 6' before turning 90 degrees.
5. LB elbows not allowed on the line side conduit
6. All corners shall be of the long sweep variety
7. Slip sleeves are required on all PVC risers
8. Maintain 6' of separation from building footing, water and sewer lines
9. Curb and gutter shall be installed prior to utility installation
10. Final grading shall be completed before underground utilities are installed
11. WREA will provide conduit plan with number and size of conduits needed for each project.
12. Approved Pull Tape shall be installed in all conduits with care taken to ensure pull tape is free to pull
13. Conduit ends shall be sealed with plug and pull tabs and extend 4" to 8" above final grade or be marked with a conduit marker
14. WREA will inspect trench before backfilling. Member/Contractor responsible for re-excavating if inspection not completed in time.
15. Compaction machinery shall not be used within 6" of conduits
16. All primary trenches shall be backfilled before services can be energized.

DESIGN: M.S.

DRAWING: A.K.

APPROVED BY: M.S.
DATE: 10/2019

URD CABLE AND TRENCHING
TRENCH REQUIREMENTS




**West River Electric
Association, Inc.**
Your Touchstone Energy® Cooperative

REV. DATE
02-20


REV. NO.
2

DRAWING NUMBER
TRENCH-1

PRIMARY UTILITY TRENCH



SECONDARY TRENCH



NOTES:

(NOT TO SCALE)

1. The sections listed below are found in this booklet and apply to this drawing.
 - a. TRENCH REQUIREMENTS
10. Member/Contractor shall allow adequate space along and around the trench for personnel to access and work during construction.
11. Member/Contractor shall furnish and install:
 - a. Survey of lot corners by Professional Land Surveyor
 - b. Approved Conduits
 - c. Trench excavation
 - d. Approved Conduit Bedding Material
 - e. Adequate Trench Compaction
12. Primary conduit shall be installed always to the outside of the trench

DESIGN: M.S.
DRAWING: A.K.
APPROVED BY: M.S.
DATE: 1/2007

TYPICAL TRENCH PROFILE TRENCH REQUIREMENTS



REV. DATE: 02-20
REV. NO.: 4

DRAWING NUMBER
TRENCH-2